

NECESAR RADIATOARE

Nr. crt.	Denumire încăpere	Temp. inter.	Necesar căldură [W]	Nr. radiat.	Tip radiator	Putere radiator [W]	Putere instalată [W]
PARTER							
1.	Atelier mecanic	18°	4877.84	1.00	22-600/2400	5,302.00	5,302.00
2.	Garaje	18°	48778.40	10.00	22-600/2400	5,302.00	53,020.00
3.	Centrala Termică	18°	9755.68	2.00	22-600/2400	5,302.00	10,604.00
4.	Grup sanitar	22°	2032.28	1.00	22-600/1000	2,209.00	2,209.00
5.	Dezinfecție	20°	1625.64	1.00	22-600/800	1,767.00	1,767.00
6.	Hol	18°	2032.28	1.00	22-600/1000	2,209.00	2,209.00
7.	Camera de zi	20°	2438.92	1.00	22-600/1200	2,651.00	2,651.00
8.	Dormitor	20°	2438.92	1.00	22-600/1200	2,651.00	2,651.00
9.	Magazie	15°	1016.60	1.00	22-600/500	1,105.00	1,105.00
10.	Casa scării	18°	3252.20	1.00	22-600/1600	3,535.00	3,535.00
ETAJ							
1.	Camera	20°	3649.64	1.00	22-600/1800	3,967.00	3,967.00
2.	Camera	20°	4877.84	1.00	22-600/2400	5,302.00	5,302.00
3.	Camera	20°	4877.84	1.00	22-600/2400	5,302.00	5,302.00
4.	Camera	20°	4877.84	1.00	22-600/2400	5,302.00	5,302.00
5.	Camera	20°	4877.84	1.00	22-600/2400	5,302.00	5,302.00
6.	Camera	20°	4877.84	1.00	22-600/2400	5,302.00	5,302.00
7.	Oficiu	18°	4064.56	1.00	22-600/2000	4,418.00	4,418.00
8.	Sala de mese	18°	4064.56	1.00	22-600/2000	4,418.00	4,418.00
9.	Coridor	18°	2438.92	1.00	22-600/1200	2,651.00	2,651.00
10.	Grup sanitar	22°	5691.12	2.00	22-600/1400	3,093.00	6,186.00
11.	Birou	20°	3251.28	1.00	22-600/1600	3,534.00	3,534.00
12.	Birou	20°	3251.28	1.00	22-600/1600	3,534.00	3,534.00
13.	Birou	20°	3251.28	1.00	22-600/1600	3,534.00	3,534.00
14.	Sala de ședințe	20°	8536.68	3.00	22-600/1400	3,093.00	9,279.00
15.	Casa scării	18°	2032.28	1.00	22-600/1000	2,209.00	2,209.00
			142869.56				155,293.00

Întocmit: ing. TOMȘA Gh.